

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 01Dated: 24-3-26

It is certified that an inspection team headed by Shri A.P. Tiwari Assistant Engineer
(Name of Officers with designation) from PHE Department Mauganj

PHED inspected the **GLOBAL ACADEMY, VILLAGE POST - BAHUTI HANUMANA ROAD, MAUGANJ, DIST. - MAUGANJ, (M. P.)** on 23-3-26 and on the basis of Water Test Report (Attached) bearing no 66/01/2026 dated 24-3-26 of PHED Water Testing Laboratory Mauganj (PHED Lab) certified that the **GLOBAL ACADEMY, VILLAGE POST - BAHUTI HANUMANA ROAD, MAUGANJ, DIST. - MAUGANJ, (M. P.)** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with seal

Name

Designation

Name & address of the office/Department: PHE Department mauganj

To,
**GLOBAL ACADEMY,
VILLAGE POST - BAHUTI HANUMANA ROAD, MAUGANJ, DIST. - MAUGANJ, (M. P.)**

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

Ainash
Principal
Global Academy
Mauganj

[Signature]
Assistant Engineer
Public Health Engg.
Dist. Mauganj, Dist. Rewa (M.P.)
:- Shri A.P. Tiwari
:- Assistant Engineer
श्री विद्योती सेवा
सेवा समिति, रीवा (म.प्र.)

DISTRICT LABORATORY PHED MAUGANJ

Public Health Engineering Department Division Mauganj

ANALYSIS REPORT

Types of sample- <u>Tubwell</u>		
PARTICULARS OF SENDER- <u>Principal Global Academy mauganj</u>		
PARTICULARS OF SAMPLE- <u>Collected/Not Collected by PHED</u>		
Sample No.	Place of collection and details of sample	DATE
(01)	<u>Global Academy School village/post- Bahuti, Block - Hanumana Distt. - mauganj</u>	<u>23-03-26</u>

PARTICULARS TO BE FILLED IN THE LABORATORY

Date of Receipt- <u>23-03-26</u>	Time of receipt- <u>110 PM</u>
Lab reference No.- <u>-</u>	Tested on- <u>24-03-2026</u>

NATURE OF STUDY -CHEMICAL & BACTERIOLOGICAL ANALYSIS

NO	Characteristics	Unit	As per BIS-10500:2012 for Drinking Water		Result				
			Requirement (Desirable Limit)	Permissible limit in the absence of Alternate Source	Sample 1	Sample 2	Sample 3	Sample 4	
					(01)				
PHYSICAL TESTS									
1	Temperature	Oc			24°C				
2	Turbidity	NTU	1.0	5.0	3.0				
3	Colour	Hazen Units	5	15	8.0				
4	Odour		Unobjectionable	Objectionable	-				
CHEMICAL TESTS									
5	PH	Ph scale	6.5 to 8.5	No Relaxation	6.65				
6	TOTAL Hardness as CaCO ₃	Mg/l	200	600	178.0				
7	Calcium as Ca	Mg/l	75	200	44.0				
8	Magnesium as MG	Mg/l	30	100	17.04				
9	Total Alkalinity as Caco ₃	Mg/l	200	600	222.5				
10	Chloride as Cl	Mg/l	250	1000	27.49				
11	Nitrate as NO ₃	Mg/l	45	45	5.0				
12	Total Dissolved Solids	Mg/l	500	2000	224				
13	Iron	Mg/l	0.3	0.3	0.14				
14	Sulphate as So ₃	Mg/l	200	400	-				
15	Fluoride as F	Mg/l	1.0	1.5	0.11				
16	Manganese as Mn	Mg/l	0.1	0.3	0.0				

Ainash
Principal
Global Academy
Mauganj

रवि
श्री किशोरी शिक्षा
सेवा समिति, रीवा (म.प्र.)

17	Residual Chlorine As CL ₂	Mg/l	0.2	1.0	0.1			
BACTERIOLOGICAL TESTS								
18	MPN of Coliform	Per 100ml	NIL		-			
19	Faecal Coliform	Per 100ml			-			

Notes- The figures indicated under the column "Requirement (Desirable Limit)" the limits unto which water is generally acceptable to the consumers. Figures in excess of those mentioned under "Requirement (Desirable Limit)" the water not acceptable, but still may be tolerated in the absence of an alternative and better source but upto the limits indicated under column "Permissible limit in the absence of Alternate Source" above which the source will have to be rejected (Guideline values for Drinking water as Per BIS 10500).

In All water intended for drinking E.Coli or thermo tolerant Coliform bacteria And Total Coliform bacteria Must not be detectable in any 100 ml sample. In case of large supplies, where sufficient sample are examined, must not be present in 95% of samples taken through out any 12 months period.

Signature of Analyst
Remarks if any

Armit
Chemist
Divisional Laboratory
PHE, Division Mauganj, Rewa (M.P.)

[Signature]
Lab Incharge
District Laboratory PHED
Mauganj (M.P.)

/No. *lab-02* // PHED/

Date *24-3-26*

Avinash
Principal
Global Academy
Mauganj

[Signature]
श्री किरण शिक्षा
सेवा समिति, सेवा (म.प्र.)